

Standard conditions		Other laying conditions	
Air temperature	30°C	$I_{\text{standard}} = \text{Standard current rating in air}$ $I_{\text{rated}} = I_{\text{standard}} \times k_1$ $k_1 = \text{Table 1}$	

Table 1 – Rating factor for variation in ambient air temperature (k_1)

Maximum conductor temperature, °C	Air temperature, °C						
	20	25	30	35	40	45	50
70	1.15	1.08	1.00	0.93	0.86	0.78	0.70
80	1.11	1.05	1.00	0.93	0.88	0.81	0.75

Disclaimer: The cable rating factors are designed as a guide for calculation of a wide range of cable types and cables sizes. While single rating factors remain reasonably accurate, the more factors that are applied simultaneously, larger possible variances arise. While every effort has been made to ensure the information contained herein is correct, CBI-electric: african cables disclaim responsibility for any action, proceedings, liabilities, claims, damages, costs, losses and expense in relation to, or arising out of any use of the factors. Due to continuous improvement CBI-electric: african cables reserves the right to change the above without notice.

electric
african cables

POWER BY INNOVATION... INNOVATION THROUGH PARTNERSHIPS

CBI-electric: african cables

B-BBEE Level 2 contributor

PO Box 172, Vereeniging 1930 - Steel Road, Peacehaven, Vereeniging 1939, South Africa

Tel: +27 16 430 6000 - Fax: +27 16 430 6235 - www.cbi-electric.com

Directors: AE Dickson, PJ Banda, GW Eddey, TA Poee, Z Mjali

Alternate Director: PW de Villiers

A member of the **REUNERT** Group
 A division of ATC (Pty) Ltd
 Registration No. 1955/003773/07

SABS
ISO 9001

SABS
ISO 14001

SABS
OHSAS 18001