

Standard laying conditions		Other laying conditions
Soil thermal resistivity	1.2K.m/W	$I_{standard}$ = Standard current rating in ground
Depth of burial	800mm	$I_{rated} = I_{standard} \times k_1 \times k_2 \times k_3 \times k_4$
Soil temperature	25°C	$k_1$ = Table 1 : $k_2$ = Table 2 : $k_3$ = Table 3 : $k_4$ = Table 4

Table 1 – Rating factors for variation in soil temperature ( $k_1$ )

Max. Conductor Temperature °C	Soil temperature °C							
	10	15	20	25	30	35	40	45
70	1.15	1.11	1.05	1.00	0.94	0.88	0.82	0.74
80	1.13	1.09	1.04	1.00	0.95	0.90	0.85	0.80

Table 2 – Rating factor for variation in thermal resistivity of soil ( $k_2$ )



	Conductor size	Soil thermal resistivity K.m/W								
		mm <sup>2</sup>	0.7	0.8	0.9	1.0	1.2	1.5	2.0	2.5
 3 Core cable	16–35	1.07	1.06	1.04	1.03	1.00	0.96	0.91	0.86	0.82
	50–120	1.09	1.07	1.05	1.03	1.00	0.96	0.89	0.84	0.80
	150–300	1.11	1.08	1.06	1.04	1.00	0.95	0.89	0.82	0.77
	3 Single Core cables	150–240	1.14	1.11	1.08	1.05	1.00	0.94	0.86	0.79
 3 Single Core cables	300–500	1.15	1.12	1.09	1.06	1.00	0.93	0.85	0.78	0.72
	630–1000	1.17	1.13	1.09	1.06	1.00	0.93	0.83	0.77	0.71

Table 3 – Rating factor for variation in depth of laying ( $k_3$ )

Depth of laying (m)	0.8	0.9	1.00	1.25	1.50	1.75	2.00	2.50	≥ 3.00
Rating factor	1.00	0.99	0.98	0.96	0.95	0.94	0.92	0.91	0.90

POWER BY INNOVATION... INNOVATION THROUGH PARTNERSHIPS

CBI-electric: african cables

B-BBEE Level 2 contributor

PO Box 172, Vereeniging 1930 - Steel Road, Peacehaven, Vereeniging 1939, South Africa

Tel: +27 16 430 6000 - Fax: +27 16 430 6235 - www.cbi-electric.com

Directors: AE Dickson, PJ Banda, GW Eddey, TA Poole, Z Mjali

Alternate Director: PW de Villiers

A member of the **REUNERT** Group  
A division of ATC (Pty) Ltd  
Registration No. 1955/003773/07



**SABS**  
ISO 9001

**SABS**  
ISO 14001

**SABS**  
OHSAS 18001

african cables

Table 4 – Group Rating factors cables in horizontal formation ( $k_4$ )

Cable Voltage	Number of Cable Circuits										
		Touching	150mm	300mm	450mm	600mm	Touching	150mm	300mm	450mm	600mm
Up to 22000V	2	0.80	0.85	0.89	0.90	0.92	0.78	0.81	0.85	0.88	0.90
	3	0.69	0.75	0.80	0.84	0.86	0.66	0.71	0.76	0.80	0.83
	4	0.63	0.70	0.77	0.80	0.84	0.60	0.65	0.72	0.76	0.80
	5	0.57	0.66	0.71	0.78	0.81	0.55	0.61	0.68	0.73	0.77
	6	0.55	0.63	0.77	0.76	0.80	0.52	0.58	0.66	0.72	0.76
33000V	2	0.80	0.83	0.87	0.89	0.91	0.79	0.81	0.85	0.88	0.90
	3	0.70	0.73	0.78	0.82	0.85	0.67	0.71	0.76	0.80	0.83
	4	0.64	0.68	0.74	0.78	0.82	0.62	0.65	0.72	0.76	0.80
	5	0.59	0.63	0.70	0.75	0.79	0.57	0.60	0.68	0.73	0.77
	6	0.56	0.60	0.68	0.74	0.78	0.54	0.57	0.66	0.72	0.76

*Disclaimer: The cable rating factors are designed as a guide for calculation of a wide range of cable types and cables sizes. While single rating factors remain reasonably accurate, the more factors that are applied simultaneously, larger possible variances arise. While every effort has been made to ensure the information contained herein is correct, CBI-electric: african cables disclaim responsibility for any action, proceedings, liabilities, claims, damages, costs, losses and expense in relation to, or arising out of any use of the factors. Due to continuous improvement CBI-electric: african cables reserves the right to change the above without notice.*